

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. <div style="text-align: center;">3</div>		3. EFFECTIVE DATE <div style="text-align: center;">See Block 16C</div>		4. REQUISITION/PURCHASE REQ. NO. <div style="text-align: center;">4200520196</div>		5. PROJECT NO. (If applicable) <div style="text-align: center;">98894.2</div>	
6. ISSUED BY <div style="text-align: center;">CODE</div>		<div style="text-align: center;">OP-ES</div>		7. ADMINISTERED BY (If other than Item 6) <div style="text-align: center;">Same as block 6</div>		<div style="text-align: center;">CODE</div>	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State, and Zip Code) <div style="text-align: center;">Potential Contractors</div>				X		9A. AMENDMENT OF SOLICITATION.	
						NNK14520196R	
						10A. MODIFICATION OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<p>[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [] is extended, [x] is not extended.</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:</p> <p>(a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor [] [] is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
<p>The purpose of Amendment 3 is to:</p> <p>A. Provide Government answers submitted by potential bidders.</p> <p>B. All other terms and conditions remain unchanged.</p>							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
(Signature of person authorized to sign)				BY _____		(Signature of Contracting Officer)	
NSN 7540-01-152-8070 PREVIOUS EDITION UNUSABLE				30-105		STANDARD FORM 30 (Rev. 10-83) Prescribed by GSA FAR (48 CFR) 53.243	

NNK14520196R – Refurbish and Upgrade Water System, LC-39B, Phase 3, PCN: 98894.2

A.) ANSWERS TO BIDDERS QUESTIONS:

- 1. REFERENCE:** Drawing Sheet M-106 and Specification Section 40 05 13 PIPELINES, LIQUID PROCESS PIPING Paragraph 2.2.4

QUESTION: Assuming the exterior of the 540 Gallon Hydro-Pneumatic Tank is to be coated per Paragraph 2.2.4, what are the coating requirements for the tank interior? We find no reference to the tank in Specification Section 09 97 13.00 40 STEEL COATINGS.

RESPONSE: Yes, the interior of the tank needs to be coated per the included table.

Surface Description	Surface Prep Type	Profile Range	First Coat/Stripe Coat/Intermediate/Finish		
Interior Steel - Carboline	SSPC SP 5	3.0 to 4.0	Carboguard 891 HS	5-7 mils/ 4-5 mils	Contrasting colors first coat and intermediate coat/white finish coat
Interior Steel - Sherwin Williams	SSPC SP 5	3.0 to 4.0	Tank Clad HS	5-7 mils/ 4-6 mils	Contrasting colors first coat and intermediate coat/white finish coat
Interior Steel - PPG	SSPC SP 5	3.0 to 4.0	Amercoat 333	3-4 mils/ 3-4 mils	Contrasting colors first coat and intermediate coat/white finish coat

B.) ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED